

# 2013 ANNUAL DRINKING WATER QUALITY REPORT

This report is a snapshot of the drinking water quality that was provided last year. Included are details about where your water came from, what it contained, and how it compared to state and federal standards. Our system makes every effort to provide you with safe and pure drinking water.

for  
**Madden Estates**  
**PWS ID #2323002**



Prepared by

**McCLURE**  
ENGINEERING, INC

*The water system at Madden Estates is owned by Arthur and Fern Maskell. If you have any questions about this report, or for additional copies, please contact the Maskells or the McClure Engineering website at <http://www.mcclureengineers.com/water.html> or office at #508.248.2005.*

**This report contains very important information about your drinking water.**  
**Please translate it, or speak with someone who understands it.**

### *Community Drinking Water Sources ~*

**M**adden Estates is located in West Brookfield, MA and until November 21, 2013 was supplied water by PWS Source ID#2323002-02G (02G) (Well #2) which is located off of Madden Road. On November 21, 2013 Well 02G was taken offline and PWS Source ID#2323002-04G (04G) (Well #4) was activated. Data in this report reflects water quality from the former Well 02G, which was active during 2013.

Madden Estates continuously strives to produce the highest quality water possible to meet or surpass every water quality standard. We monitor our water source and distribution system very closely. The standards we operate under were enacted by the U.S. Congress as the Safe Drinking Water Act in 1974 and were amended in 1986 and 1996.

### *Is My Water Treated?*

To ensure that we provide the highest quality of water available, certified operators and MassDEP regularly monitor water quality. When standards are exceeded, MassDEP requires treatment. Well 02G was disinfected with sodium hypochlorite as its primary disinfectant to protect you against microbial contaminants. Disinfection does not sterilize the water but it does destroy harmful organisms. Sterilization kills all microorganisms, even though most are not harmful, and is too costly to use on a routine basis. Chlorine destroys organisms by penetrating cell walls and reacting with enzymes. Disinfection with chlorine has been proven effective at ensuring that water is free of harmful organisms and safe to drink. Chlorine disinfection is no longer used but is available for emergency situations. Currently Well 04G is treated with a water softener for the removal of iron and manganese and an acid neutralizer to control (raise) the pH level. Water is regenerated with a sodium chloride brine rinse.

### *Substances Found in Tap Water ~*

Sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- ***Microbial contaminants***, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ***Inorganic contaminants***, such as salts and metals, which can be naturally occurring or result from urban storm water runoff or domestic wastewater discharges oil and gas production, mining, or farming.
- ***Pesticides and herbicides***, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- ***Organic chemical contaminants***, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production. These contaminants can also come from gasoline storage, urban storm water runoff, and septic systems.
- ***Radioactive contaminants***, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Department of Environmental Protection (MassDEP) and US Environmental Protection Agency (EPA) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water that must provide the same protection for public health. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers. EPA/CDC guidelines on appropriate mean to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

# DISTRIBUTION SYSTEM WATER QUALITY

The quality information presented in the tables below is from the most recent round of testing done in accordance with the regulations. All data shown was collected during the last calendar year unless otherwise noted in the tables.

Bacteria 2013	Highest # Positive Samples in a Month	MCL	MCLG	Violation (Y/N)	Possible Sources
Total Coliform	18	1	0	Y	Naturally present in the environment
E. Coli	0	*	0	N	Human and animal fecal waste

Coliform are bacteria that are naturally present in the environment and are used as an indicator of potentially harmful bacteria that may be present. \*Compliance with the Fecal Coliform/E.coli MCL is determined upon additional repeat testing.

Lead & Copper	Last Date Collected	90 <sup>th</sup> Percentile	Action Level (AL)	MCLG	# of sites sampled	# of sites above Action Level	Exceeds Action Level	Possible Sources of Contamination
Lead (ppb)	9/5/13	131	15	0	5	2	Y	Corrosion of household plumbing; erosion of natural deposits
Copper (ppm)	9/5/13	.988	1.3	1.3	5	1	No	Corrosion of household plumbing; erosion of natural deposits; leaching from wood preservatives.

Lead and copper sampling is scheduled twice annually. The last samples collected were in September 2013, and the next sample collection will be from the new PWS Source 04G during Quarter 2 of 2014.

*“Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.” If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Madden Estates is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.”*

## Cross Connection Control and Prevention

Cross connections are the links through which it is possible for contaminating materials to enter a potable water supply. The contaminant enters the potable water system when the pressure of the polluted source exceeds the pressure of the potable source. The action may be called backsiphonage or backflow. Essentially it is reversal of the hydraulic gradient that can be produced by a variety of circumstances. A cross connection is an actual or potential connection between a drinking water pipe and a polluted source. The pollution can come from your own home. Using a backflow prevention device on your hose connection when washing your car, for example, can prevent backsiphonage of car wash chemicals into a water supply.

Madden Estates recommends the installation of low-cost hose bibb vacuum breakers for all inside and outside threaded spigots and hoses. You can purchase them at a hardware store or plumbing supply store. This is a great way to help protect the water system that serves your home and community!

# SUMMARY OF FINISHED WATER CHARACTERISTICS

Regulated Contaminants	Date Collected	Highest Result or Highest Avg Detected	Range detected	MCL	MCLG	Violation (Y/N)	Possible Sources
<b>Inorganic Contaminants</b>							
Nitrate (ppm)	April 1, 2013	1.24	1.24	10	10	N	Runoff from fertilizer use; leaching from septic tanks; erosion of natural deposits
Arsenic (ppb)	Annual 2012	ND	ND	10	-	N	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production waste
Perchlorate (ppb)	Annual 2011	0.083	0.083	2.0	N/A	N	Rockep propellants, fireworks, munitions, flares, blasting agents
<b>Disinfectants and Disinfection Byproducts</b>							
Free Chlorine (ppm)	2013	0.50	0.08-1.54	4	4	N	Water additive used to control microbes
Total Trihalomethane (TTHM) (ppb)	August 2012	11	11	80	--	N	Byproduct of drinking water chlorination
Total Haloacetic Acids (HAA5) (ppb)	August 2012	18	18	60	--	N	Byproduct of drinking water chlorination

Unregulated Contaminants*	Last Date Collected	Result or Range Detected	Avg Detected	SMCL (ppb)	ORSG	Possible Sources
<b>Inorganic Contaminants</b>						
Sodium (ppm)	June 26, 2012	8.3	8.3	--	20	Natural sources; runoff from road salt; byproduct treatment
<b>Secondary Contaminants</b>						
Iron (ppb)	June 27, 2011	870	870	300	--	Naturally occurring, corrosion of cast iron pipes
Manganese* (ppb)	June 27, 2011	30	30	50	Health advisory of 300 ppb	Erosion of natural deposits

\*Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist regulatory agencies in determining their occurrence in drinking water and whether future regulation is warranted. MassDEP recommends the annual sampling for Secondary Contaminants at Madden Estates.

The MassDEP has reduced the monitoring requirements for Gross Alpha Particle Activity, Radium 226 & 228 because the system is not at risk of contamination. Gross Alpha Particle Activity, Radium 226 & Radium 228, and Synthetic Organic Contaminants will be sampled in 2015 at the new Source 04G.

**Perchlorate:** Perchlorate interferes with the normal function of the thyroid gland and thus has the potential to affect growth and development, causing brain damage and other adverse effects, particularly in fetuses and infants. Pregnant women, the fetus, infants, children up to the age of 12, and people with a hypothyroid condition are particularly susceptible to perchlorate toxicity. **\*Manganese:** US EPA has established a lifetime health advisory (HA) value of 300 ppb for manganese to protect against concerns of potential neurological effects, and a one-day and 10-day HA of 1000 ppb for acute exposure. Drinking water may naturally have manganese and, when concentrations are greater than 50 µg/L, the water may be discolored and taste bad. Over a lifetime, EPA recommends that people drink water with manganese levels less than 300 µg/L and over the short term, EPA recommends that people limit their consumption of water with levels over 1000 µg/L, primarily due to concerns about possible neurological effects. Children up to 1 year of age should not be given water with manganese concentrations over 300 µg/L, nor should formula for infants be made with that water for longer than 10 days.

## ~ IMPORTANT DEFINITIONS ~

**Maximum Contaminant Level (MCL)** – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Secondary Maximum Contaminant Level (SMCL)** – These standards are developed to protect the aesthetic qualities of drinking water and are not health based.

**Massachusetts Office of Research and Standards Guideline (ORSG)** – This is the concentration of a chemical in drinking water, at or below which, adverse health effects are unlikely to occur after chronic (lifetime) exposure. If exceeded, it serves as an indicator of the potential need for further action.

**Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**90<sup>th</sup> Percentile** – Out of every 10 homes sampled, 9 were at or below this level.

**ppm** = parts per million, or milligrams per liter (mg/l)

**ppb** = parts per billion, or micrograms per liter (ug/l)

**pCi/l** = picocuries per liter, or micrograms per liter (ug/l)

**ND** = Not Detected

**N/A** = Not Applicable

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

## ~ EDUCATIONAL INFORMATION ~

### SWAP (Source Water Assessment and Protection)

MassDEP has prepared a Source Water Assessment and Protection (SWAP) report for Madden Estates. The report assesses the susceptibility of public water supplies to contamination and makes recommendations. This report is available at the office of McClure Engineering at 5 Masonic Home Road, Charlton, MA and the MassDEP website <http://www.mass.gov/eea/docs/dep/water/drinking/swap/cero/2323002.pdf>.

MassDEP assigned a susceptibility ranking of **Moderate** has been assigned to the wells in our system based on the presence of moderate threat land use or activity within the water supply protection area.

If you have any questions, please contact McClure Engineering at 508-248-2005.

### Opportunities to Participate ~

Any matters that concern your drinking water supply or issues you would like to see addressed can be presented at the regularly scheduled meeting of the trustees, association or board. If your concerns need immediate attention contact System Owner, Arthur Maskell at 508-867-7972.

### Water System Improvements ~

Our water system is routinely inspected by MassDEP for its technical, financial and managerial capacity to provide safe drinking water to you. MassDEP issued an Administrative Consent Order, ACOP-CE-09-5D003-Amend 1 (ACOP) that required the system to permit and construct a new public water supply source to serve the community and to abandon and decommission existing water sources.

On October 28, 2012 the MassDEP issued a verbal notice of, and on November 2, 2012 the MassDEP issued a Boil Water Order (ENF#UAO-CE-12-5D007) to Madden Estates due to noncompliance with the monthly MCL for total coliform because more than one sample collected during the month of October 2012 was positive for total coliform (bacteria). The PWS also had mechanical issues and was unable to provide adequate disinfection. The Boil Order directed Madden Estates to evaluate the cause of the bacteria contamination, take corrective action, and notify customers to either boil their water for at least one minute before consuming, or to consume water from an alternative source approved by the MassDEP until further notice. The Boil Order Notice was provided to all residents at Madden Estates via door to door hand-delivery on October 29, 2012, as certified by the Owner as well as additional times throughout the year. On November 21, 2013 the new PWS Source ID#2323002-04G (04G) was activated and the Boil Order was terminated by the MassDEP on December 23, 2013. Treatment for 04G was installed for the reduction of iron and manganese and to raise the pH levels in order to provide corrosion control.

**This report prepared by McClure Engineering, Inc.**

**Also available at <http://www.mcclureengineers.com/water.html>**

This notice for PWS ID# 2323002 was distributed by Fern Maskell by July 1, 2014

