

2025 ANNUAL DRINKING WATER QUALITY REPORT

This report is a snapshot of the drinking water quality that was provided last year. Included are details about where your water came from, what it contained, and how it compared to state and federal standards. Our system makes every effort to provide you with safe and pure drinking water.

for
Millbury Industrial Park/Park Hill Village
PWS ID #2186001



Prepared by

McCLURE
ENGINEERING, INC

The water system is owned by Millbury Industrial Park/Park Hill Village. For additional copies, please contact Antonio Cartolano (Millbury Industrial Park), Frank Croghan (Park Hill Village) or the McClure Engineering website at <https://mcclureengineers.com/consumer-confidence-reports/> or office at 508.248.2005.

This report contains very important information about your drinking water.
Please translate it, or speak with someone who understands it.

Community Drinking Water Source

Millbury Industrial Park/Park Hill Village is located in Millbury, MA, and its water is purchased from the City of Worcester.

Data in this report reflects water quality from Millbury Industrial Park/Park Hill Village.

Millbury Industrial Park/Park Hill Village continuously strives to distribute the highest quality water possible to meet or surpass every water quality standard. We monitor our water source and distribution system very closely. The standards we operate under were enacted by the U.S. Congress as the Safe Drinking Water Act in 1974 and were amended in 1986 and 1996.

Is My Water Treated?

To ensure that we provide the highest quality of water available, certified operators and MassDEP regularly monitor water quality. When standards are exceeded, MassDEP requires treatment.

Substances Found in Tap Water ~

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by emailing the US Environmental Protection Agency (EPA) at safewater@epa.gov.

Sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff or domestic wastewater discharges, oil and gas production, mining, and farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants** can be naturally occurring or be the result of oil and gas production and mining activities.
- **Unregulated Contaminants** are those for which EPA has not established drinking water standards. The purpose of unregulated monitoring is to assist EPA in determining their occurrence in drinking water and whether future regulation is warranted.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available by emailing the EPA at safewater@epa.gov.

In order to ensure that tap water is safe to drink, the Department of Environmental Protection (MassDEP) and EPA prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

~ CROSS CONNECTION CONTROL AND PREVENTION ~


Millbury Industrial Park/Park Hill Village makes every effort to ensure that the water delivered to your home and business is clean, safe and free of contamination. Our staff works very hard to protect the quality of the water delivered to our customers from the time the water is extracted via deep wells from underground aquifers or withdrawal point from a surface water source, throughout the entire treatment and distribution system. But what happens when the water reaches your home or business? Is there still a need to protect the water quality from contamination caused by a cross-connection? If so, how?

What is a cross-connection?

A cross-connection occurs whenever the drinking water supply is or could be in contact with potential sources of pollution or contamination. Cross-connections exist in piping arrangements or equipment that allows the drinking water to come in contact with non-potable liquids, solids, or gases (hazardous to humans) in the event of a backflow.

To What is a backflow?

Backflow is the undesired reverse of the water flow in the drinking water distribution lines. This backward flow of water can occur when the pressure created by equipment or a system such as a boiler or air-conditioning is higher than the water pressure inside the water distribution line (back pressure), or when the pressure in the distribution line drops due to routine occurrences such as water main breaks or heavy water demand causing the water to flow backward inside the water distribution system (back siphonage). Backflow is a problem that many water consumers are unaware of, and a problem that each and every water customer has a responsibility to help prevent.



What can I do to help prevent a cross-connection?

Without the proper protection, something as simple as a garden hose has the potential to contaminate or pollute the drinking water lines in your house. In fact over half of the country's cross-connection incidents involve unprotected garden hoses.

There are very simple steps that you as a drinking water user can take to prevent such hazards. They are:

- NEVER submerge a hose in soapy water buckets, pet watering containers, pool, tubs, sinks, drains, or chemicals.
- NEVER attached a hose to a garden sprayer without the proper backflow preventer.
- Buy and install a hose bibb vacuum breaker in any threaded water fixture. The installation can be as easy as attaching a garden hose to a spigot. This inexpensive device is available at most hardware stores and home-improvement centers.
- Identify and be aware of potential cross-connections to your water line.
- Buy appliances and equipment with backflow preventers.
- Buy and install backflow prevention devices or assemblies for all high and moderate hazard connections.

Charlton Manor recommends the installation of low-cost hose bibb vacuum breakers for all inside and outside threaded spigots and hoses. You can purchase them at a hardware store or plumbing supply store. This is a great way to help protect the water system that serves your home and community!

~ *IMPORTANT DEFINITIONS* ~

Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) –The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL) – The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

90th Percentile – Out of every 10 homes sampled, 9 were at or below this level. This number is compared to the Action Level to determine lead and copper compliance.

Secondary Maximum Contaminant Level (SMCL) – These standards are developed to protect aesthetic qualities of drinking water and are not health-based.

Office of Research and Standards Guideline (ORSG) – This is the concentration of a chemical in drinking water, at or below which, adverse health effects are unlikely to occur after chronic (lifetime) exposure. If exceeded, it serves as an indicator of the potential need for further action.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

ppm = parts per million, or milligrams per liter (mg/l)

ppb = parts per billion, or micrograms per liter (ug/l)

ppt = parts per trillion, or nanograms per liter (ng/l)

pCi/l = picocuries per liter (measure of radioactivity)

C.U= color units (measure of the intensity of color in water)

ND = Not Detected

N/A = Not Applicable

DISTRIBUTION SYSTEM WATER QUALITY

What Does This Data Represent?

The water quality information presented in the table is from the most recent round of testing done in accordance with the regulations. All data shown was collected during the last calendar year unless otherwise noted in the table.

| | Site 1 | Site 2 | Site 3 | Site 4 | Site 5 | Site 6 | Site 7 | Site 8 | Site 9 | Site 10 |
|--------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|
| Lead (ppb) | ND | ND | ND | ND | 1 | ND | ND | ND | ND | ND |
| Copper (ppm) | 0.0644 | 0.0448 | 0.0718 | 0.0754 | 0.1160 | 0.0269 | 0.0432 | 0.1040 | 0.0920 | 0.0492 |

| Lead & Copper | Last Date Collected | Range Detected | * 90 th Percentile | Action Level (AL) | MCLG | # of sites sampled | # of sites above Action Level | Exceeds Action Level | Possible Sources of Contamination |
|---|---------------------|----------------|-------------------------------|-------------------|------|--------------------|-------------------------------|----------------------|---|
| Lead (ppb) | September 2023 | 0-1 | 0 | 15 | 0 | 5 | 0 | N | Corrosion of household plumbing; erosion of natural Deposits. |
| Copper (ppm) | September 2023 | 0.0269-0.1160 | 0.104 | 1.3 | 1.3 | 5 | 0 | N | Corrosion of household plumbing; erosion of natural deposits; leaching from wood preservatives. |
| <p>*Millbury Industrial Park/Park Hill Village was required to collect 10 lead and copper samples. The 9th highest result is the 90th Percentile. Lead and copper compliance is determined by comparing the 90th percentile value to the Action Level (AL) for each contaminant. The AL is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.</p> <p>Lead and copper compliance sampling is conducted triennially.</p> | | | | | | | | | |

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson’s Disease should consult their personal doctor.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **Millbury Industrial Park/Park Hill Village** is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. Because lead levels may vary overtime, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family’s risk.

Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead in drinking water is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly.

Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Antonio Cartolano at 914-843-9290 (Millbury Industrial Park) or Frank Crohan at 774-253-0549 (Park Hill Village). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

DISTRIBUTION SYSTEM WATER QUALITY (continued)

| Regulated Contaminants | Date Collected | Highest Result or Highest Avg | Range detected | MCL | MCLG | Violation (Y/N) | Possible Sources |
|--|--------------------------------------|-------------------------------|----------------|-----|------|-----------------|---|
| Inorganic Contaminants | | | | | | | |
| Asbestos (ppb) | 5/19/2021 | ND | ND | 6 | 6 | N | Decay of asbestos cement water mains; Erosion of natural deposits. |
| Haloacetic Acids (ppb) (quarterly) | 5/22/2025 8/21/2025 11/19/2025 | 49.5 | 38.1-69 | 60 | N/A | N | By-product of drinking water disinfection. |
| Trihalomethanes (ppb) (quarterly) | 5/22/2025 8/21/2025 11/19/2025 | 73.2 | 61.4-86.7 | 80 | N/A | N | By-product of drinking water disinfection. |
| Turbidity [SEC] (NTU) | 9/20/2023 | 1.6 | N/A | TT | N/A | N | Soil runoff. |
| -Secondary Contaminants [SEC] were sampled on 9/20/2023. <u>SECs were non-detected unless listed above.</u> MassDEP recommends annual testing. | | | | | | | |

DISTRIBUTION SYSTEM WATER QUALITY (continued)

| Unregulated and Secondary Contaminants ¹ | Last Date Collected | Result or Range Detected | Average Detected | SMCL | ORSG | Possible Sources |
|---|--------------------------------------|--------------------------|------------------|---------|------------------------|---|
| Aluminum [SEC] (ppb) | 9/20/2023 | 83 | N/A | 200 | NA | Residue from water treatment process; erosion of natural deposits. |
| Bromodichloromethane (ppb) | 5/22/2025 8/21/2025 11/19/2025 | 6.66-11.7 | 15.03 | NA | NA | Trihalomethane; by-product of drinking water chlorination. |
| Bromoform (ppb) | 5/22/2025 8/21/2025 11/19/2025 | ND | ND | NA | NA | Trihalomethane; by-product of drinking water chlorination. |
| Chloride [SEC] (ppm) | 9/20/2023 | 31.1 | N/A | 250 | NA | Runoff and leaching from natural deposits; seawater influence. |
| Chloroform (ppb) | 5/22/2025 8/21/2025 11/19/2025 | 47.6-73.3 | 61.63 | NA | NA | Trihalomethane; by-product of drinking water chlorination. |
| Color [SEC] (C.U) | 9/30/2023 | 10 | N/A | 15 | NA | -- |
| Copper [SEC] (ppm) | 9/20/2023 | 0.244 | N/A | 1 | NA | Internal corrosion of household plumbing; erosion of natural deposits. |
| Dibromochloromethane (ppb) | 5/22/2025 8/21/2025 11/19/2025 | 0.8-2.13 | 1.52 | NA | NA | Trihalomethane; by-product of drinking water chlorination. |
| Iron [SEC] (ppb) | 9/20/2023 | 174 | N/A | 300 | NA | Natural and industrial sources as well as aging and corroding distribution systems and household pipes. |
| Manganese ² [SEC] (ppb) | 9/20/2023 | 41 | N/A | 50 | Health advisory of 300 | Natural sources as well as discharges from industrial uses. |
| pH [SEC] | 9/30/2023 | 7.32 | N/A | 6.5-8.5 | NA | Runoff and leaching from natural deposits; seawater influence. |
| Sulfate [SEC] (ppm) | 9/30/2023 | 8.7 | N/A | 250 | NA | Runoff and leaching from natural deposits; industrial wastes. |
| Total Dissolved Solids (ppm) | 9/30/2023 | 77 | N/A | 500 | NA | Runoff and leaching from natural deposits; seawater influence. |
| Zinc [SEC] (ppm) | 9/30/2023 | 0.014 | N/A | 5 | NA | Corrosion of household plumbing systems; erosion of natural deposits. |

¹Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist US EPA in determining their occurrence in drinking water and whether future regulation is warranted.

²US EPA and MassDEP have established public Health Advisory (HA) levels for manganese to protect against concerns of potential neurological effects and a one-day and 10-day HA of 1000 ppb for acute exposure.

~ EDUCATIONAL INFORMATION ~

SWAP (Source Water Assessment and Protection) ~

MassDEP has not prepared a Source Water Assessment Program (SWAP) Report for Millbury Industrial Park/Park Hill Village. The report assesses the susceptibility of the public water supply to contamination and makes recommendations.

Residents can help protect sources by:

- Practicing good septic system maintenance
- Supporting water supply protection initiatives at the next town meeting
- Taking hazardous household chemicals to hazardous materials collection days
- Limiting pesticides, fertilizer uses, and unnecessary outdoor watering

Opportunities to Participate ~

Any matters that concern your drinking water supply or issues you would like to see addressed can be presented at the regularly scheduled meeting of the trustees, association or board. If your concerns need immediate attention contact Antonio Cartolano at 914-843-9290 (Millbury Industrial Park) or Frank Crohan at 774-253-0549 (Park Hill Village).

Water System Improvements ~

Our water system is routinely inspected by MassDEP for its technical, financial and managerial capacity to provide safe drinking water to you. The PWS continues to monitor the water and make adjustments when necessary.

Millbury Industrial Park/Park Hill Village

PWS ID# 2186001

12 Latti Farm Road

Millbury, MA 01527

914-843-9290

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information please contact:

Millbury Industrial Park/Park Hill Village

PWS ID# 2186001

12 Latti Farm Road

Millbury, MA 01527

#914.743.9290

This report was prepared by McClure Engineering, Inc.

Also available at <http://www.mcclureengineers.com/>

This notice for **PWS ID# 2186001** was distributed by McClure Engineering/Millbury Industrial Park/Park Hill Village

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER



**Massachusetts Department of Environmental Protection
Bureau of Water Resources - Drinking Water Program**

**MONITORING AND REPORTING VIOLATION
NOTICE OF NONCOMPLIANCE (NON)**

M.G.L. c.21A sec. 16, 310 CMR 5.00

Enforcement Notice:

NON-CE-25-5D00020022-CSA

A PWS Information and Mailing Address:

PARK HILL VILLAGE HOMEOWNERS TRUST
CHRISTOPHER VINCENT AND SARAH JAWLOR, TRUSTEES
PO BOX 281
MILLBURY, MA 01527

ENF DATE: 3/5/2025

PWSID: 2186001

CLASS: COM

TOWN: MILLBURY

B Location Where Noncompliance Occurred: MILLBURY IND. PARK/ PARK HILL VILLAGE

| Period | Type | Contaminant Group | Comments |
|----------------------|--------|------------------------------|------------------------|
| 10/1/2024 12/31/2024 | MRDBPR | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 12/1/2024 12/31/2024 | MRDBPR | CHLORINE RESIDUAL, TOTAL | (2 SITES) TC001, TC002 |
| 12/1/2024 12/31/2024 | MONROU | REVISED TOTAL COLIFORM RULE | (2 SITES) TC001, TC002 |

C Description of Violations under M.G.L. c. 111 sec. 159-160 and 310 CMR 22.00

The Department of Environmental Protection (MassDEP), Drinking Water Program, has not received the public water system's (PWS's) monitoring results and/or MassDEP has received an incomplete submittal for the contaminant(s) and monitoring period(s) specified in Section B. Therefore, the public water system is in violation of one or more of the following Monitoring and Reporting requirements:

- Failure to report to MassDEP analytical results for the contaminant(s) and monitoring period(s) specified in Section B, as required by 310 CMR 22.15(2) and/or 310 CMR 22.03(13);
- Failure to monitor for the contaminant(s) and monitoring period(s) set forth in Section B, as required by 310 CMR 22.03(1), 310 CMR 22.03(2) and/or 310 CMR 22.03(10).
- Failure to notify MassDEP of the PWS's failure to monitor, as required by 310 CMR 22.15(1)a.

D Corrective Actions to Take and Deadline for Taking Such Actions

The PWS must submit appropriate sample results for the contaminants and locations listed in Section B, or submit a proposed schedule detailing how and when the system will meet applicable monitoring and public notice requirements by following the steps below. The PWS will return to compliance after all applicable monitoring, reporting, and public notification requirements have been completed.

Within thirty (30) days receipt of this Notice of Noncompliance (NON):

1. If the PWS has collected and analyzed samples for the contaminant(s) and locations listed above in Section B, submit to the appropriate MassDEP Regional Office a copy of the sampling results or electronic eDEP transmittal receipt; and a completed response form (see enclosed Monitoring and Reporting Violation Response and Compliance Schedule Approval).
2. If the PWS has NOT collected and analyzed samples for the contaminant(s) and locations listed in Section B, submit a completed response form to the appropriate MassDEP Regional Office to obtain required approvals (see enclosed Monitoring and Reporting Violation Response and Compliance Schedule Approval).
3. If the PWS has completed applicable public notice requirements, submit to the appropriate MassDEP Regional Office a copy of the distributed public notice(s) and completed public notice certification form (see enclosures).

E Important Information

If the PWS fails to take MassDEP required actions by the prescribed deadline, or if the PWS otherwise fails to remain in compliance in the future with applicable requirements, the PWS could be subject to legal action including, but not limited to, criminal prosecution, court-imposed civil penalties, or civil administrative penalties assessed by MassDEP. A civil administrative penalty may be assessed for every day from now on that the PWS is in noncompliance with the requirements specified above. MassDEP reserves its right to exercise the full extent of its legal authority in order to obtain compliance with all applicable requirements.

For any questions about this NON please contact Lauren Sullivan at Lauren.M.Sullivan@mass.gov

**Robert A. Bostwick - Drinking Water Program Chief
MassDEP Central Regional Office**

cc: MassDEP BOSTON, BOH, DWP CERO (File Copy)

Certified Operator: _____

MONITORING AND REPORTING VIOLATION RESPONSE AND COMPLIANCE SCHEDULE APPROVAL

A General Information PWSID: **2186001** CLASS: **COM**

Reference # **NON-CE-25-5D00020022-CSA**

PWS Name: **MILLBURY IND. PARK/ PARK HILL VILLAGE**

ENF Issued Date: **3/5/2025**

B Instructions Please select and complete either Option 1 or 2 in Section C and sign Section D.

Within thirty (30) days of receipt of the referenced Notice of Noncompliance (NON) for monitoring and/or reporting violations, the Public Water System (PWS) must complete and submit this response form and supporting documentation to the MassDEP Regional Office listed below. It is understood that if Option 1 is checked, the PWS compliance plan will be deemed approved upon MassDEP receipt of the completed form. If Option 2 is checked, MassDEP will notify the PWS if the proposed compliance plan has been approved.

C Corrective Actions for Reporting and/or Monitoring Violations

OPTION 1: MassDEP Approval of Pre-Determined Compliance Plan

Reporting Violations: *If the PWS DID collect and analyze samples during the proper monitoring periods for ALL of the contaminants and locations listed in the NON:* **check one of the following two statements, then skip to Section D.**

The PWS DID REPORT the results to MassDEP in the required format, by the applicable deadline. Attached is a copy of the monitoring results (or eDEP transmittal receipt) for the contaminants identified in the NON and documentation to demonstrate that the results were collected and properly reported to MassDEP within the appropriate timeframe.

MassDEP will review documentation and re-evaluate PWS compliance status. No corrective actions required at this time.

The PWS DID NOT REPORT the results to MassDEP in the required format, by the applicable deadline. Attached is a copy of the monitoring results (or eDEP transmittal receipt) for the contaminants identified in the NON.

PWS will report applicable monitoring to MassDEP as specified in 310 CMR 22.15(2). No additional actions required at this time.

Monitoring Violations: *If the PWS DID NOT collect samples during the required monitoring periods for ALL of the contaminants and locations listed in the NON:* **complete the Monitoring and Public Notification sections then skip to Section D.**

MONITORING For each contaminant group and location in the table below, provide the date of sample collection (for samples taken after the violation period), or the date (or period) the sample is planned to be collected.

- Within 30 days of receipt of the NON, the PWS either has collected or will collect and analyze the required samples to return to compliance with the requirements cited as indicated in the following table; and submit to MassDEP a copy of the monitoring results.
- Monitoring for sources or sample locations that are currently off-line or unavailable will be collected upon planned reactivation, as indicated in the following table.

Note: For contaminants with special seasonal sampling periods, specific ONLY to: annual or triennial Lead and Copper (Q3: July-Sep); Microscopic Particulate Analysis (MPA) in (Spring: 4/1-5/30 or Fall: 8/15-10/15); or annual or triennial TTHM/HAA5 (Aug); monitoring must be conducted during the same period the following year, unless otherwise determined by MassDEP. For LCR violations, a full (new) LCR sample set must be collected at all approved locations during the same period the following year. Contact your MassDEP regional office for details. (PWS must monitor in accordance with the specific contaminant sampling criteria to return to compliance.)

| Violation Period | Contaminant Group | Location | Date Collected or | Planned Sample Date or Period |
|------------------------|------------------------------|------------------------|-------------------|-------------------------------|
| 12/1/2024 - 12/31/2024 | REVISED TOTAL COLIFORM RULE | (2 SITES) TC001, TC002 | 5/22/2025 | |
| 12/1/2024 - 12/31/2024 | CHLORINE RESIDUAL, TOTAL | (2 SITES) TC001, TC002 | 5/22/2025 | |
| 10/1/2024 - 12/31/2024 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET | | 7/31/2026 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Massachusetts Department of Environmental Protection - Drinking Water Program M&R - CSA
MONITORING AND REPORTING VIOLATION RESPONSE AND COMPLIANCE SCHEDULE APPROVAL

PWSID: **2186001**

Reference #: **NON-CE-24-5D00020022-CSA**

OPTION 1 (continued):

PUBLIC NOTIFICATION

- The PWS will provide Tier 3 public notification in accordance with 310 CMR 22.16(4) by one or more of the following delivery methods within one year of the NON issued date. (check appropriate boxes)

Community systems (COM):

- Direct Mail Hand Delivery Newspaper 1-day advertisement CCR (by direct delivery only)

Non-Community systems (NTNC and TNC):

- Direct Mail Hand Delivery Posting for a minimum of 7 days in conspicuous locations

- The PWS will submit certification to MassDEP and the local Board of Health within 10 days of completing public notification. Such notification will include a copy of the distributed public notice.

OPTION 2: PWS Proposed Compliance Plan (Requiring MassDEP Approval)

If Option 1 is not selected or the PWS is unable to complete Option 1 requirements, the PWS must submit a proposed Compliance Plan for MassDEP approval. A proposed Compliance Plan MUST include a schedule for returning to compliance with each of the monitoring and reporting violations cited in the NON and address applicable public notification requirements.

The PWS has included a proposed plan for MassDEP review and approval detailing the specific actions it intends to take to return to compliance and, as appropriate, to prevent future noncompliance. It is understood that MassDEP will provide written notification (which may be via e-mail) if the PWS's proposed Compliance Plan and Schedule is approved.

Proposed Compliance Plan Description and Schedule (enclose additional explanation/attachments as necessary):

The PWS contracted McClure Engineering, Inc. (McClure) for certified operations starting in May 2025. McClure began collecting the required samples and submitting the appropriate documentation to the MassDEP.

D Certification - Water Commissioner, Owner, Owner Representative or other Responsible Party:

I certify that under penalty of law I am duly authorized to complete and submit this form on behalf of the public water system identified above and that the information contained herein is true, accurate and complete to the best of my knowledge and belief. I understand that MassDEP may assess civil administrative penalties in accordance with M.G.L. c. 21A, s.16, and 310 CMR 5.00 to any Supplier of Water that fails to comply with the provisions and schedule set forth in a MassDEP-approved Compliance Plan.

Signature: _____

Date: _____

Print Name: _____

Title: _____

Email Address: _____

Phone#: _____

Please complete this response form and return it with all required attachments to:

MassDEP CERO - Drinking Water Program, 8 New Bond Street, Worcester, MA 01606

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

DRINKING WATER NOTICE Monitoring Requirements Not Met for:

PWS NAME: MILLBURY IND. PARK/ PARK HILL VILLAGE

We violated monitoring and reporting requirements of the drinking water regulations. Even though this was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this

We are required to monitor your drinking water for specific man-made and naturally occurring contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the monitoring period(s) listed below we did not monitor and/or did not complete all monitoring for the contaminant(s) listed below and therefore cannot be sure of the quality of our drinking water during that time.

WHAT THIS MEANS: **There is nothing you need to do at this time.**

The table below lists the contaminant(s) we did not properly test for and/or report to the Department of Environmental Protection (DEP) during the required monitoring period(s).

| Monitoring Period | Contaminant Group | Violation Comments |
|----------------------|------------------------------|------------------------|
| 10/1/2024 12/31/2024 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 12/1/2024 12/31/2024 | CHLORINE RESIDUAL, TOTAL | (2 SITES) TC001, TC002 |
| 12/1/2024 12/31/2024 | REVISED TOTAL COLIFORM RULE | (2 SITES) TC001, TC002 |

STEPS WE ARE TAKING:

In response to monitoring and reporting violations of the Massachusetts Drinking Water Regulations, our system is taking the following corrective actions:

1. We are notifying our customers of the violation(s) by providing this public notice to you as well as submitting a copy of this public notice to the MassDEP and local board of health.
2. Sample Collection (check appropriate boxes):
 - We have scheduled to collect and analyze sample(s) for the contaminants listed above and will submit copies of the sampling results to the MassDEP upon completion.
 - We have already collected and analyzed sample(s) for the contaminants listed above and have submitted copies of the sampling results to the DEP. These contaminant(s) were collected AFTER the required monitoring period(s) on: 5/22/2025 [Date].
3. We will continue to collect samples for all contaminants according to our most recent sampling schedule.
4. Other Corrective Actions Taken:

CONTACT INFORMATION:

Please share this information with all people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information or questions regarding this notice, please contact:

Responsible Party Name: _____ at Phone #: _____

CERTIFICATION:

DEP Reference Number: NON-CE-25-5D00020022-CSA PWSID: 2186001

The Public Water system indicated above hereby affirms that public notice has been provided to consumers in accordance with 310 CMR 22.16 including: delivery, content, format requirements, notification deadlines and that the Public Water system will meet future requirements for notifying new billing units and new customers of the violation. I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Notice Distributed by: CCR on 7/1/2026
[Delivery Method] [Date]

Notice Distributed by: _____ on _____
[Delivery Method] [Date]

Signature of Responsible Party

Date

**Massachusetts Department of Environmental Protection
Drinking Water Program
PUBLIC NOTIFICATION**

CERTIFICATION

Make sure to send your regional office of the MassDEP Drinking Water Program and local Board of Health a copy of each type of notice and a certification that you have met all the public notice requirements within ten days after issuing the notice (310 CMR 22.15(3)b).

PWSID: **2186001**

DEP Reference Number: **NON-CE-25-5D00020022-CSA**

PWS NAME: **MILLBURY IND. PARK/ PARK HILL VILLAGE**

TOWN: **MILLBURY**

CLASS: **COM**

For Monitoring and/or Reporting Violation(s) Occurring on:

| Monitoring Period | Contaminant Group | Violation Comments |
|----------------------|------------------------------|------------------------|
| 10/1/2024 12/31/2024 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 12/1/2024 12/31/2024 | CHLORINE RESIDUAL, TOTAL | (2 SITES) TC001, TC002 |
| 12/1/2024 12/31/2024 | REVISED TOTAL COLIFORM RULE | (2 SITES) TC001, TC002 |

The Public Water system indicated above hereby affirms that public notice has been provided to consumers in accordance with 310 CMR 22.16 including: delivery, content, format requirements, notification deadlines and that the Public Water system will meet future requirements for notifying new billing units and new customers of the violation.

Delivery Method(s) and Date(s) of Delivery: Check one or more method as applicable, and fill in appropriate date(s).

Community systems (COM):

- Direct Mail on (Date): _____
- Hand Delivery on (Date): _____
- Newspaper 1-day advertisement on (Date): _____
- CCR (by direct delivery only) on (Date): 7/1/2026
- Other _____ on (Date): _____

Non-community systems (NTNC and TNC):

- Direct Mail on (Date): _____
- Hand Delivery on (Date): _____
- Posting for minimum of 7-days in conspicuous locations on (Date): _____
- Other _____ on (Date): _____

I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Print Name

Signature of Responsible Party

Date

SUBMIT THIS FORM WITH A COPY OF YOUR PUBLIC NOTICE(S) TO MassDEP AND LOCAL BOARD OF HEALTH WITHIN 10 DAYS AFTER ISSUING THE NOTICE



**Massachusetts Department of Environmental Protection
Bureau of Water Resources - Drinking Water Program**

**MONITORING AND REPORTING VIOLATION
NOTICE OF NONCOMPLIANCE (NON)**

M.G.L. c.21A sec. 16, 310 CMR 5.00

Enforcement Notice:

NON-CE-25-5D00020870-CSA

A PWS Information and Mailing Address:

**PARK HILL VILLAGE HOMEOWNERS TRUST
CHRISTOPHER VINCENT AND SARAH JAWLOR, TRUSTEES
PO BOX 281
MILLBURY, MA 01527**

ENF DATE: 7/3/2025

PWSID: 2186001

CLASS: COM

TOWN: MILLBURY

B Location Where Noncompliance Occurred: MILLBURY IND. PARK/ PARK HILL VILLAGE

| Period | Type | Contaminant Group | Comments |
|----------------------|--------|---|-------------------|
| 12/1/2024 12/31/2024 | MRIESW | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (DEC) |
| 1/1/2025 1/31/2025 | MRIESW | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (JAN) |
| 2/1/2025 2/28/2025 | MRIESW | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (FEB) |
| 3/1/2025 3/31/2025 | MRIESW | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (MAR) |

C Description of Violations under M.G.L. c. 111 sec. 159-160 and 310 CMR 22.00

The Department of Environmental Protection (MassDEP), Drinking Water Program, has not received the public water system's (PWS's) monitoring results and/or MassDEP has received an incomplete submittal for the contaminant(s) and monitoring period(s) specified in Section B. Therefore, the public water system is in violation of one or more of the following Monitoring and Reporting requirements:

- Failure to report to MassDEP analytical results for the contaminant(s) and monitoring period(s) specified in Section B, as required by 310 CMR 22.15(2) and/or 310 CMR 22.03(13);
- Failure to monitor for the contaminant(s) and monitoring period(s) set forth in Section B, as required by 310 CMR 22.03(1), 310 CMR 22.03(2) and/or 310 CMR 22.03(10).
- Failure to notify MassDEP of the PWS's failure to monitor, as required by 310 CMR 22.15(1)a.

D Corrective Actions to Take and Deadline for Taking Such Actions

The PWS must submit appropriate sample results for the contaminants and locations listed in Section B, or submit a proposed schedule detailing how and when the system will meet applicable monitoring and public notice requirements by following the steps below. The PWS will return to compliance after all applicable monitoring, reporting, and public notification requirements have been completed.

Within thirty (30) days receipt of this Notice of Noncompliance (NON):

1. If the PWS has collected and analyzed samples for the contaminant(s) and locations listed above in Section B, submit to the appropriate MassDEP Regional Office a copy of the sampling results or electronic eDEP transmittal receipt; and a completed response form (see enclosed Monitoring and Reporting Violation Response and Compliance Schedule Approval).
2. If the PWS has NOT collected and analyzed samples for the contaminant(s) and locations listed in Section B, submit a completed response form to the appropriate MassDEP Regional Office to obtain required approvals (see enclosed Monitoring and Reporting Violation Response and Compliance Schedule Approval).
3. If the PWS has completed applicable public notice requirements, submit to the appropriate MassDEP Regional Office a copy of the distributed public notice(s) and completed public notice certification form (see enclosures).

E Important Information

If the PWS fails to take MassDEP required actions by the prescribed deadline, or if the PWS otherwise fails to remain in compliance in the future with applicable requirements, the PWS could be subject to legal action including, but not limited to, criminal prosecution, court-imposed civil penalties, or civil administrative penalties assessed by MassDEP. A civil administrative penalty may be assessed for every day from now on that the PWS is in noncompliance with the requirements specified above. MassDEP reserves its right to exercise the full extent of its legal authority in order to obtain compliance with all applicable requirements.

For any questions about this NON please contact Lauren Sullivan at Lauren.M.Sullivan@mass.gov

**Robert A. Bostwick - Drinking Water Program Chief
MassDEP Central Regional Office**

cc: MassDEP BOSTON, BOH, DWP CERO (File Copy)

Certified Operator: _____

MONITORING AND REPORTING VIOLATION RESPONSE AND COMPLIANCE SCHEDULE APPROVAL

A General Information PWSID: **2186001** CLASS: **COM** Reference # **NON-CE-25-5D00020870-CSA**
 PWS Name: **MILLBURY IND. PARK/ PARK HILL VILLAGE** ENF Issued Date: **7/3/2025**

B Instructions Please select and complete either Option 1 or 2 in Section C and sign Section D.
Within thirty (30) days of receipt of the referenced Notice of Noncompliance (NON) for monitoring and/or reporting violations, the Public Water System (PWS) must complete and submit this response form and supporting documentation to the MassDEP Regional Office listed below. It is understood that if Option 1 is checked, the PWS compliance plan will be deemed approved upon MassDEP receipt of the completed form. If Option 2 is checked, MassDEP will notify the PWS if the proposed compliance plan has been approved.

C Corrective Actions for Reporting and/or Monitoring Violations

OPTION 1: MassDEP Approval of Pre-Determined Compliance Plan

Reporting Violations: If the PWS DID collect and analyze samples during the proper monitoring periods for ALL of the contaminants and locations listed in the NON: **check one of the following two statements, then skip to Section D.**

- The PWS DID REPORT the results to MassDEP in the required format, by the applicable deadline. Attached is a copy of the monitoring results (or eDEP transmittal receipt) for the contaminants identified in the NON and documentation to demonstrate that the results were collected and properly reported to MassDEP within the appropriate timeframe.
MassDEP will review documentation and re-evaluate PWS compliance status. No corrective actions required at this time.
- The PWS DID NOT REPORT the results to MassDEP in the required format, by the applicable deadline. Attached is a copy of the monitoring results (or eDEP transmittal receipt) for the contaminants identified in the NON.
PWS will report applicable monitoring to MassDEP as specified in 310 CMR 22.15(2). No additional actions required at this time.

Monitoring Violations: If the PWS DID NOT collect samples during the required monitoring periods for ALL of the contaminants and locations listed in the NON: **complete the Monitoring and Public Notification sections then skip to Section D.**

MONITORING For each contaminant group and location in the table below, provide the date of sample collection (for samples taken after the violation period), or the date (or period) the sample is planned to be collected.

- Within 30 days of receipt of the NON, the PWS either has collected or will collect and analyze the required samples to return to compliance with the requirements cited as indicated in the following table; and submit to MassDEP a copy of the monitoring results.
- Monitoring for sources or sample locations that are currently off-line or unavailable will be collected upon planned reactivation, as indicated in the following table.

Note: For contaminants with special seasonal sampling periods, specific ONLY to: annual or triennial Lead and Copper (Q3: July-Sep); Microscopic Particulate Analysis (MPA) in (Spring: 4/1-5/30 or Fall: 8/15-10/15); or annual or triennial TTHM/HAA5 (Aug); monitoring must be conducted during the same period the following year, unless otherwise determined by MassDEP. For LCR violations, a full (new) LCR sample set must be collected at all approved locations during the same period the following year. Contact your MassDEP regional office for details. (PWS must monitor in accordance with the specific contaminant sampling criteria to return to compliance.)

| Violation Period | Contaminant Group | Location | Date Collected or | Planned Sample Date or Period |
|------------------------|---|-------------------|-------------------|-------------------------------|
| 3/1/2025 - 3/31/2025 | INTERIM ENHANCED SURFACE WATER TREAT MAGENT BLUE | SWTR FORM G (MAR) | | 7/31/2026 |
| 2/1/2025 - 2/28/2025 | INTERIM ENHANCED SURFACE WATER TREAT MAGENT BLUE | SWTR FORM G (FEB) | | 7/31/2026 |
| 1/1/2025 - 1/31/2025 | INTERIM ENHANCED SURFACE WATER TREAT MAGENT BLUE | SWTR FORM G (JAN) | | 7/31/2026 |
| 12/1/2024 - 12/31/2024 | INTERIM ENHANCED SURFACE WATER TREAT MAGENT BLUE | SWTR FORM G (DEC) | | 7/31/2026 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

MONITORING AND REPORTING VIOLATION RESPONSE AND COMPLIANCE SCHEDULE APPROVAL

PWSID: 2186001

Reference #: NON-CE-25-5D00020870-CSA

OPTION 1 (continued):

PUBLIC NOTIFICATION

- The PWS will provide Tier 3 public notification in accordance with 310 CMR 22.16(4) by one or more of the following delivery methods within one year of the NON issued date. (check appropriate boxes)

Community systems (COM):

- Direct Mail, Hand Delivery, Newspaper 1-day advertisement, CCR (by direct delivery only)

Non-Community systems (NTNC and TNC):

- Direct Mail, Hand Delivery, Posting for a minimum of 7 days in conspicuous locations

- The PWS will submit certification to MassDEP and the local Board of Health within 10 days of completing public notification. Such notification will include a copy of the distributed public notice.

OPTION 2: PWS Proposed Compliance Plan (Requiring MassDEP Approval)

If Option 1 is not selected or the PWS is unable to complete Option 1 requirements, the PWS must submit a proposed Compliance Plan for MassDEP approval. A proposed Compliance Plan MUST include a schedule for returning to compliance with each of the monitoring and reporting violations cited in the NON and address applicable public notification requirements.

The PWS has included a proposed plan for MassDEP review and approval detailing the specific actions it intends to take to return to compliance and, as appropriate, to prevent future noncompliance. It is understood that MassDEP will provide written notification (which may be via e-mail) if the PWS's proposed Compliance Plan and Schedule is approved.

Proposed Compliance Plan Description and Schedule (enclose additional explanation/attachments as necessary):

The PWS contracted McClure Engineering, Inc. (McClure) for certified operations starting in May 2025. McClure began collecting the required samples and submitting the appropriate documentation to the MassDEP.

D Certification - Water Commissioner, Owner, Owner Representative or other Responsible Party:

I certify that under penalty of law I am duly authorized to complete and submit this form on behalf of the public water system identified above and that the information contained herein is true, accurate and complete to the best of my knowledge and belief. I understand that MassDEP may assess civil administrative penalties in accordance with M.G.L. c. 21A, s.16, and 310 CMR 5.00 to any Supplier of Water that fails to comply with the provisions and schedule set forth in a MassDEP-approved Compliance Plan.

Signature: _____

Date: _____

Print Name: _____

Title: _____

Email Address: _____

Phone#: _____

Please complete this response form and return it with all required attachments to:

MassDEP CERO - Drinking Water Program, 8 New Bond Street, Worcester, MA 01606

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

DRINKING WATER NOTICE

Monitoring Requirements Not Met for:

PWS NAME:

MILLBURY IND. PARK/ PARK HILL VILLAGE

We violated monitoring and reporting requirements of the drinking water regulations. Even though this was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this situation.

We are required to monitor your drinking water for specific man-made and naturally occurring contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the monitoring period(s) listed below we did not monitor and/or did not complete all monitoring for the contaminant(s) listed below and therefore cannot be sure of the quality of our drinking water during that time.

WHAT THIS MEANS: There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for and/or report to the Department of Environmental Protection (DEP) during the required monitoring period(s).

| Monitoring Period | Contaminant Group | Violation Comments |
|----------------------|---|--------------------|
| 12/1/2024 12/31/2024 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (DEC) |
| 1/1/2025 1/31/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (JAN) |
| 2/1/2025 2/28/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (FEB) |
| 3/1/2025 3/31/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (MAR) |

STEPS WE ARE TAKING:

In response to monitoring and reporting violations of the Massachusetts Drinking Water Regulations, our system is taking the following corrective actions:

1. We are notifying our customers of the violation(s) by providing this public notice to you as well as submitting a copy of this public notice to the MassDEP and local board of health.
2. Sample Collection (check appropriate boxes):
 - We have scheduled to collect and analyze sample(s) for the contaminants listed above and will submit copies of the sampling results to the MassDEP upon completion.
 - We have already collected and analyzed sample(s) for the contaminants listed above and have submitted copies of the sampling results to the DEP. These contaminant(s) were collected AFTER the required monitoring period(s) on: _____ [Date].
3. We will continue to collect samples for all contaminants according to our most recent sampling schedule.
4. Other Corrective Actions Taken:

CONTACT INFORMATION:

Please share this information with all people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information or questions regarding this notice, please contact:

Responsible Party Name: _____

at Phone #: _____

CERTIFICATION:

DEP Reference Number: **NON-CE-25-5D00020870-CSA**

PWSID: **2186001**

The Public Water system indicated above hereby affirms that public notice has been provided to consumers in accordance with 310 CMR 22.16 including: delivery, content, format requirements, notification deadlines and that the Public Water system will meet future requirements for notifying new billing units and new customers of the violation. I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Notice Distributed by: CCR on 7/1/2026
[Delivery Method] [Date]

Notice Distributed by: _____ on _____
[Delivery Method] [Date]

Signature of Responsible Party

Date



**Massachusetts Department of Environmental Protection
Bureau of Water Resources - Drinking Water Program**

**MONITORING AND REPORTING VIOLATION
NOTICE OF NONCOMPLIANCE (NON)**

M.G.L. c.21A sec. 16, 310 CMR 5.00

Enforcement Notice:

NON-CE-25-5D00020871-CSA

A PWS Information and Mailing Address:

**PARK HILL VILLAGE HOMEOWNERS TRUST
CHRISTOPHER VINCENT AND SARAH JAWLOR, TRUSTEES
PO BOX 281
MILLBURY, MA 01527**

ENF DATE: 7/3/2025

PWSID: 2186001

CLASS: COM

TOWN: MILLBURY

B Location Where Noncompliance Occurred: MILLBURY IND. PARK/ PARK HILL VILLAGE

| Period | Type | Contaminant Group | Comments |
|----------------------|--------|---|----------------------------------|
| 10/1/2024 12/31/2024 | MRDBPR | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 1/1/2025 3/31/2025 | MRDBPR | DISINFECTION BYPRODUCTS RULE | MONTHLY CHLORINE (JAN, FEB, MAR) |
| 1/1/2025 3/31/2025 | MRDBPR | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 4/1/2025 6/30/2025 | MRDBPR | DISINFECTION BYPRODUCTS RULE | MONTHLY CHLORINE (APR, MAY) |
| 5/1/2025 5/31/2025 | MRISW | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G(MAY) |

C Description of Violations under M.G.L. c. 111 sec. 159-160 and 310 CMR 22.00

The Department of Environmental Protection (MassDEP), Drinking Water Program, has not received the public water system's (PWS's) monitoring results and/or MassDEP has received an incomplete submittal for the contaminant(s) and monitoring period(s) specified in Section B. Therefore, the public water system is in violation of one or more of the following Monitoring and Reporting requirements:

- Failure to report to MassDEP analytical results for the contaminant(s) and monitoring period(s) specified in Section B, as required by 310 CMR 22.15(2) and/or 310 CMR 22.03(13);
- Failure to monitor for the contaminant(s) and monitoring period(s) set forth in Section B, as required by 310 CMR 22.03(1), 310 CMR 22.03(2) and/or 310 CMR 22.03(10).
- Failure to notify MassDEP of the PWS's failure to monitor, as required by 310 CMR 22.15(1)a.

D Corrective Actions to Take and Deadline for Taking Such Actions

The PWS must submit appropriate sample results for the contaminants and locations listed in Section B, or submit a proposed schedule detailing how and when the system will meet applicable monitoring and public notice requirements by following the steps below. The PWS will return to compliance after all applicable monitoring, reporting, and public notification requirements have been completed.

Within thirty (30) days receipt of this Notice of Noncompliance (NON):

1. If the PWS has collected and analyzed samples for the contaminant(s) and locations listed above in Section B, submit to the appropriate MassDEP Regional Office a copy of the sampling results or electronic eDEP transmittal receipt; and a completed response form (see enclosed Monitoring and Reporting Violation Response and Compliance Schedule Approval).
2. If the PWS has NOT collected and analyzed samples for the contaminant(s) and locations listed in Section B, submit a completed response form to the appropriate MassDEP Regional Office to obtain required approvals (see enclosed Monitoring and Reporting Violation Response and Compliance Schedule Approval).
3. If the PWS has completed applicable public notice requirements, submit to the appropriate MassDEP Regional Office a copy of the distributed public notice(s) and completed public notice certification form (see enclosures).

E Important Information

If the PWS fails to take MassDEP required actions by the prescribed deadline, or if the PWS otherwise fails to remain in compliance in the future with applicable requirements, the PWS could be subject to legal action including, but not limited to, criminal prosecution, court-imposed civil penalties, or civil administrative penalties assessed by MassDEP. A civil administrative penalty may be assessed for every day from now on that the PWS is in noncompliance with the requirements specified above. MassDEP reserves its right to exercise the full extent of its legal authority in order to obtain compliance with all applicable requirements.

For any questions about this NON please contact Lauren Sullivan at Lauren.M.Sullivan@mass.gov

**Robert A. Bostwick - Drinking Water Program Chief
MassDEP Central Regional Office**

cc: MassDEP BOSTON, BOH, DWP CERO (File Copy)

Certified Operator: _____

MONITORING AND REPORTING VIOLATION RESPONSE AND COMPLIANCE SCHEDULE APPROVAL

A General Information PWSID: **2186001** CLASS: **COM** Reference # **NON-CE-25-5D00020871-CSA**
 PWS Name: **MILLBURY IND. PARK/ PARK HILL VILLAGE** ENF Issued Date: **7/3/2025**

B Instructions Please select and complete either Option 1 or 2 in Section C and sign Section D.
Within thirty (30) days of receipt of the referenced Notice of Noncompliance (NON) for monitoring and/or reporting violations, the Public Water System (PWS) must complete and submit this response form and supporting documentation to the MassDEP Regional Office listed below. It is understood that if Option 1 is checked, the PWS compliance plan will be deemed approved upon MassDEP receipt of the completed form. If Option 2 is checked, MassDEP will notify the PWS if the proposed compliance plan has been approved.

C Corrective Actions for Reporting and/or Monitoring Violations

OPTION 1: MassDEP Approval of Pre-Determined Compliance Plan

Reporting Violations: If the PWS DID collect and analyze samples during the proper monitoring periods for ALL of the contaminants and locations listed in the NON: **check one of the following two statements, then skip to Section D.**

- The PWS DID REPORT the results to MassDEP in the required format, by the applicable deadline. Attached is a copy of the monitoring results (or eDEP transmittal receipt) for the contaminants identified in the NON and documentation to demonstrate that the results were collected and properly reported to MassDEP within the appropriate timeframe.
MassDEP will review documentation and re-evaluate PWS compliance status. No corrective actions required at this time.
- The PWS DID NOT REPORT the results to MassDEP in the required format, by the applicable deadline. Attached is a copy of the monitoring results (or eDEP transmittal receipt) for the contaminants identified in the NON.
PWS will report applicable monitoring to MassDEP as specified in 310 CMR 22.15(2). No additional actions required at this time.

Monitoring Violations: If the PWS DID NOT collect samples during the required monitoring periods for ALL of the contaminants and locations listed in the NON: **complete the Monitoring and Public Notification sections then skip to Section D.**

MONITORING For each contaminant group and location in the table below, provide the date of sample collection (for samples taken after the violation period), or the date (or period) the sample is planned to be collected.

- Within 30 days of receipt of the NON, the PWS either has collected or will collect and analyze the required samples to return to compliance with the requirements cited as indicated in the following table; and submit to MassDEP a copy of the monitoring results.
- Monitoring for sources or sample locations that are currently off-line or unavailable will be collected upon planned reactivation, as indicated in the following table.

Note: For contaminants with special seasonal sampling periods, specific ONLY to: annual or triennial Lead and Copper (Q3: July-Sep); Microscopic Particulate Analysis (MPA) in (Spring: 4/1-5/30 or Fall: 8/15-10/15); or annual or triennial TTHM/HAA5 (Aug); monitoring must be conducted during the same period the following year, unless otherwise determined by MassDEP. For LCR violations, a full (new) LCR sample set must be collected at all approved locations during the same period the following year. Contact your MassDEP regional office for details. (PWS must monitor in accordance with the specific contaminant sampling criteria to return to compliance.)

| Violation Period | Contaminant Group | Location | Date Collected or | Planned Sample Date or Period |
|------------------------|---|----------------------------------|-------------------|-------------------------------|
| 4/1/2025 - 6/30/2025 | DISINFECTION BYPRODUCTS RULE | MONTHLY CHLORINE (APR, MAY) | 9/19/2025 | (MAY) |
| 5/1/2025 - 5/31/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G(MAY) | | 7/31/2026 |
| 10/1/2024 - 12/31/2024 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET | | 7/31/2026 |
| 1/1/2025 - 3/31/2025 | DISINFECTION BYPRODUCTS RULE | MONTHLY CHLORINE (JAN, FEB, MAR) | 9/19/2025 | |
| 1/1/2025 - 3/31/2025 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET | | 7/31/2026 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

MONITORING AND REPORTING VIOLATION RESPONSE AND COMPLIANCE SCHEDULE APPROVAL

PWSID: 2186001

Reference #: NON-CE-25-5D00020871-CSA

OPTION 1 (continued):

PUBLIC NOTIFICATION

- The PWS will provide Tier 3 public notification in accordance with 310 CMR 22.16(4) by one or more of the following delivery methods within one year of the NON issued date. (check appropriate boxes)

Community systems (COM):

- Direct Mail, Hand Delivery, Newspaper 1-day advertisement, CCR (by direct delivery only)

Non-Community systems (NTNC and TNC):

- Direct Mail, Hand Delivery, Posting for a minimum of 7 days in conspicuous locations

- The PWS will submit certification to MassDEP and the local Board of Health within 10 days of completing public notification. Such notification will include a copy of the distributed public notice.

OPTION 2: PWS Proposed Compliance Plan (Requiring MassDEP Approval)

If Option 1 is not selected or the PWS is unable to complete Option 1 requirements, the PWS must submit a proposed Compliance Plan for MassDEP approval. A proposed Compliance Plan MUST include a schedule for returning to compliance with each of the monitoring and reporting violations cited in the NON and address applicable public notification requirements.

The PWS has included a proposed plan for MassDEP review and approval detailing the specific actions it intends to take to return to compliance and, as appropriate, to prevent future noncompliance. It is understood that MassDEP will provide written notification (which may be via e-mail) if the PWS's proposed Compliance Plan and Schedule is approved.

Proposed Compliance Plan Description and Schedule (enclose additional explanation/attachments as necessary):

The PWS contracted McClure Engineering, Inc. (McClure) for certified operations starting in May 2025. McClure began collecting the required samples and submitting the appropriate documentation to the MassDEP.

D Certification - Water Commissioner, Owner, Owner Representative or other Responsible Party:

I certify that under penalty of law I am duly authorized to complete and submit this form on behalf of the public water system identified above and that the information contained herein is true, accurate and complete to the best of my knowledge and belief. I understand that MassDEP may assess civil administrative penalties in accordance with M.G.L. c. 21A, s.16, and 310 CMR 5.00 to any Supplier of Water that fails to comply with the provisions and schedule set forth in a MassDEP-approved Compliance Plan.

Signature: _____ Date: _____

Print Name: _____ Title: _____

Email Address: _____ Phone#: _____

Please complete this response form and return it with all required attachments to:

MassDEP CERO - Drinking Water Program, 8 New Bond Street, Worcester, MA 01606

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

DRINKING WATER NOTICE

Monitoring Requirements Not Met for:

PWS NAME:

MILLBURY IND. PARK/ PARK HILL VILLAGE

We violated monitoring and reporting requirements of the drinking water regulations. Even though this was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this situation.

We are required to monitor your drinking water for specific man-made and naturally occurring contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the monitoring period(s) listed below we did not monitor and/or did not complete all monitoring for the contaminant(s) listed below and therefore cannot be sure of the quality of our drinking water during that time.

WHAT THIS MEANS: There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for and/or report to the Department of Environmental Protection (DEP) during the required monitoring period(s).

| Monitoring Period | Contaminant Group | Violation Comments |
|----------------------|---|----------------------------------|
| 10/1/2024 12/31/2024 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 1/1/2025 3/31/2025 | DISINFECTION BYPRODUCTS RULE | MONTHLY CHLORINE (JAN, FEB, MAR) |
| 1/1/2025 3/31/2025 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 4/1/2025 6/30/2025 | DISINFECTION BYPRODUCTS RULE | MONTHLY CHLORINE (APR, MAY) |
| 5/1/2025 5/31/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G(MAY) |

STEPS WE ARE TAKING:

In response to monitoring and reporting violations of the Massachusetts Drinking Water Regulations, our system is taking the following corrective actions:

1. We are notifying our customers of the violation(s) by providing this public notice to you as well as submitting a copy of this public notice to the MassDEP and local board of health.
2. Sample Collection (check appropriate boxes):
 - We have scheduled to collect and analyze sample(s) for the contaminants listed above and will submit copies of the sampling results to the MassDEP upon completion.
 - We have already collected and analyzed sample(s) for the contaminants listed above and have submitted copies of the sampling results to the DEP. These contaminant(s) were collected AFTER the required monitoring period(s) on: _____ [Date].
3. We will continue to collect samples for all contaminants according to our most recent sampling schedule.
4. Other Corrective Actions Taken:

CONTACT INFORMATION:

Please share this information with all people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information or questions regarding this notice, please contact:

Responsible Party Name: _____ at Phone #: _____

CERTIFICATION:

DEP Reference Number: **NON-CE-25-5D00020871-CSA** PWSID: **2186001**

The Public Water system indicated above hereby affirms that public notice has been provided to consumers in accordance with 310 CMR 22.16 including: delivery, content, format requirements, notification deadlines and that the Public Water system will meet future requirements for notifying new billing units and new customers of the violation. I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Notice Distributed by: CCR on 7/1/2026
[Delivery Method] [Date]

Notice Distributed by: _____ on _____
[Delivery Method] [Date]

Signature of Responsible Party

Date

**Massachusetts Department of Environmental Protection
Drinking Water Program
PUBLIC NOTIFICATION**

CERTIFICATION

Make sure to send your regional office of the MassDEP Drinking Water Program and local Board of Health a copy of each type of notice and a certification that you have met all the public notice requirements within ten days after issuing the notice (310 CMR 22.15(3)b).

PWSID: **2186001**

DEP Reference Number: **NON-CE-25-5D00020871-CSA**

PWS NAME: **MILLBURY IND. PARK/ PARK HILL VILLAGE**

TOWN: **MILLBURY**

CLASS: **COM**

For Monitoring and/or Reporting Violation(s) Occurring on:

| Monitoring Period | Contaminant Group | Violation Comments |
|----------------------|---|----------------------------------|
| 10/1/2024 12/31/2024 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 1/1/2025 3/31/2025 | DISINFECTION BYPRODUCTS RULE | MONTHLY CHLORINE (JAN, FEB, MAR) |
| 1/1/2025 3/31/2025 | DISINFECTION BYPRODUCTS RULE | DBPR WORKSHEET |
| 4/1/2025 6/30/2025 | DISINFECTION BYPRODUCTS RULE | MONTHLY CHLORINE (APR, MAY) |
| 5/1/2025 5/31/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G(MAY) |

The Public Water system indicated above hereby affirms that public notice has been provided to consumers in accordance with 310 CMR 22.16 including: delivery, content, format requirements, notification deadlines and that the Public Water system will meet future requirements for notifying new billing units and new customers of the violation.

Delivery Method(s) and Date(s) of Delivery: Check one or more method as applicable, and fill in appropriate date(s).

Community systems (COM):

- Direct Mail on (Date): _____
- Hand Delivery on (Date): _____
- Newspaper 1-day advertisement on (Date): _____
- CCR (by direct delivery only) on (Date): 7/1/2026
- Other _____ on (Date): _____

Non-community systems (NTNC and TNC):

- Direct Mail on (Date): _____
- Hand Delivery on (Date): _____
- Posting for minimum of 7-days in conspicuous locations on (Date): _____
- Other _____ on (Date): _____

I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Print Name

Signature of Responsible Party

Date

SUBMIT THIS FORM WITH A COPY OF YOUR PUBLIC NOTICE(S) TO MassDEP AND LOCAL BOARD OF HEALTH WITHIN 10 DAYS AFTER ISSUING THE NOTICE



**Massachusetts Department of Environmental Protection
Bureau of Water Resources - Drinking Water Program**

**MONITORING AND REPORTING VIOLATION
NOTICE OF NONCOMPLIANCE (NON)**

M.G.L. c.21A sec. 16, 310 CMR 5.00

Enforcement Notice:

NON-CE-25-5D00020872-CSA

A PWS Information and Mailing Address:

**PARK HILL VILLAGE HOMEOWNERS TRUST
CHRISTOPHER VINCENT AND SARAH JAWLOR, TRUSTEES
PO BOX 281
MILLBURY, MA 01527**

ENF DATE: 7/3/2025

PWSID: 2186001

CLASS: COM

TOWN: MILLBURY

B Location Where Noncompliance Occurred: MILLBURY IND. PARK/ PARK HILL VILLAGE

| Period | Type | Contaminant Group | Comments |
|--------------------|--------|---|--------------------|
| 1/1/2025 1/31/2025 | MONROU | REVISED TOTAL COLIFORM RULE | TC001, TC002 (JAN) |
| 2/1/2025 2/28/2025 | MONROU | REVISED TOTAL COLIFORM RULE | TC001, TC002 (FEB) |
| 3/1/2025 3/31/2025 | MONROU | REVISED TOTAL COLIFORM RULE | TC001, TC002 (MAR) |
| 4/1/2025 4/30/2025 | MRISW | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (APR) |
| 4/1/2025 4/30/2025 | MONROU | REVISED TOTAL COLIFORM RULE | TC001, TC002 (APR) |

C Description of Violations under M.G.L. c. 111 sec. 159-160 and 310 CMR 22.00

The Department of Environmental Protection (MassDEP), Drinking Water Program, has not received the public water system's (PWS's) monitoring results and/or MassDEP has received an incomplete submittal for the contaminant(s) and monitoring period(s) specified in Section B. Therefore, the public water system is in violation of one or more of the following Monitoring and Reporting requirements:

- Failure to report to MassDEP analytical results for the contaminant(s) and monitoring period(s) specified in Section B, as required by 310 CMR 22.15(2) and/or 310 CMR 22.03(13);
- Failure to monitor for the contaminant(s) and monitoring period(s) set forth in Section B, as required by 310 CMR 22.03(1), 310 CMR 22.03(2) and/or 310 CMR 22.03(10).
- Failure to notify MassDEP of the PWS's failure to monitor, as required by 310 CMR 22.15(1)a.

D Corrective Actions to Take and Deadline for Taking Such Actions

The PWS must submit appropriate sample results for the contaminants and locations listed in Section B, or submit a proposed schedule detailing how and when the system will meet applicable monitoring and public notice requirements by following the steps below. The PWS will return to compliance after all applicable monitoring, reporting, and public notification requirements have been completed.

Within thirty (30) days receipt of this Notice of Noncompliance (NON):

1. If the PWS has collected and analyzed samples for the contaminant(s) and locations listed above in Section B, submit to the appropriate MassDEP Regional Office a copy of the sampling results or electronic eDEP transmittal receipt; and a completed response form (see enclosed Monitoring and Reporting Violation Response and Compliance Schedule Approval).
2. If the PWS has NOT collected and analyzed samples for the contaminant(s) and locations listed in Section B, submit a completed response form to the appropriate MassDEP Regional Office to obtain required approvals (see enclosed Monitoring and Reporting Violation Response and Compliance Schedule Approval).
3. If the PWS has completed applicable public notice requirements, submit to the appropriate MassDEP Regional Office a copy of the distributed public notice(s) and completed public notice certification form (see enclosures).

E Important Information

If the PWS fails to take MassDEP required actions by the prescribed deadline, or if the PWS otherwise fails to remain in compliance in the future with applicable requirements, the PWS could be subject to legal action including, but not limited to, criminal prosecution, court-imposed civil penalties, or civil administrative penalties assessed by MassDEP. A civil administrative penalty may be assessed for every day from now on that the PWS is in noncompliance with the requirements specified above. MassDEP reserves its right to exercise the full extent of its legal authority in order to obtain compliance with all applicable requirements.

For any questions about this NON please contact Lauren Sullivan at Lauren.M.Sullivan@mass.gov

**Robert A. Bostwick - Drinking Water Program Chief
MassDEP Central Regional Office**

cc: MassDEP BOSTON, BOH, DWP CERO (File Copy)

Certified Operator: _____

MONITORING AND REPORTING VIOLATION RESPONSE AND COMPLIANCE SCHEDULE APPROVAL

A General Information PWSID: **2186001** CLASS: **COM** Reference # **NON-CE-25-5D00020872-CSA**
 PWS Name: **MILLBURY IND. PARK/ PARK HILL VILLAGE** ENF Issued Date: **7/3/2025**

B Instructions Please select and complete either Option 1 or 2 in Section C and sign Section D.
Within thirty (30) days of receipt of the referenced Notice of Noncompliance (NON) for monitoring and/or reporting violations, the Public Water System (PWS) must complete and submit this response form and supporting documentation to the MassDEP Regional Office listed below. It is understood that if Option 1 is checked, the PWS compliance plan will be deemed approved upon MassDEP receipt of the completed form. If Option 2 is checked, MassDEP will notify the PWS if the proposed compliance plan has been approved.

C Corrective Actions for Reporting and/or Monitoring Violations

OPTION 1: MassDEP Approval of Pre-Determined Compliance Plan

Reporting Violations: *If the PWS DID collect and analyze samples during the proper monitoring periods for ALL of the contaminants and locations listed in the NON: check one of the following two statements, then skip to Section D.*

- The PWS DID REPORT the results to MassDEP in the required format, by the applicable deadline. Attached is a copy of the monitoring results (or eDEP transmittal receipt) for the contaminants identified in the NON and documentation to demonstrate that the results were collected and properly reported to MassDEP within the appropriate timeframe.
MassDEP will review documentation and re-evaluate PWS compliance status. No corrective actions required at this time.
- The PWS DID NOT REPORT the results to MassDEP in the required format, by the applicable deadline. Attached is a copy of the monitoring results (or eDEP transmittal receipt) for the contaminants identified in the NON.
PWS will report applicable monitoring to MassDEP as specified in 310 CMR 22.15(2). No additional actions required at this time.

Monitoring Violations: *If the PWS DID NOT collect samples during the required monitoring periods for ALL of the contaminants and locations listed in the NON: complete the Monitoring and Public Notification sections then skip to Section D.*

MONITORING For each contaminant group and location in the table below, provide the date of sample collection (for samples taken after the violation period), or the date (or period) the sample is planned to be collected.

- Within 30 days of receipt of the NON, the PWS either has collected or will collect and analyze the required samples to return to compliance with the requirements cited as indicated in the following table; and submit to MassDEP a copy of the monitoring results.
- Monitoring for sources or sample locations that are currently off-line or unavailable will be collected upon planned reactivation, as indicated in the following table.

Note: For contaminants with special seasonal sampling periods, specific ONLY to: annual or triennial Lead and Copper (Q3: July-Sep); Microscopic Particulate Analysis (MPA) in (Spring: 4/1-5/30 or Fall: 8/15-10/15); or annual or triennial TTHM/HAA5 (Aug); monitoring must be conducted during the same period the following year, unless otherwise determined by MassDEP. For LCR violations, a full (new) LCR sample set must be collected at all approved locations during the same period the following year. Contact your MassDEP regional office for details. (PWS must monitor in accordance with the specific contaminant sampling criteria to return to compliance.)

| Violation Period | Contaminant Group | Location | Date Collected or Planned Sample Date or Period |
|----------------------|---|--------------------|---|
| 2/1/2025 - 2/28/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (FEB) | 5/22/2025 |
| 1/1/2025 - 1/31/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (JAN) | 5/22/2025 |
| 3/1/2025 - 3/31/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (MAR) | 5/22/2025 |
| 4/1/2025 - 4/30/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (APR) | 7/31/2026 |
| 4/1/2025 - 4/30/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (APR) | 5/22/2025 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

MONITORING AND REPORTING VIOLATION RESPONSE AND COMPLIANCE SCHEDULE APPROVAL

PWSID: 2186001

Reference #: NON-CE-25-5D00020872-CSA

OPTION 1 (continued):

PUBLIC NOTIFICATION

- The PWS will provide Tier 3 public notification in accordance with 310 CMR 22.16(4) by one or more of the following delivery methods within one year of the NON issued date. (check appropriate boxes)

Community systems (COM):

- Direct Mail, Hand Delivery, Newspaper 1-day advertisement, CCR (by direct delivery only)

Non-Community systems (NTNC and TNC):

- Direct Mail, Hand Delivery, Posting for a minimum of 7 days in conspicuous locations

- The PWS will submit certification to MassDEP and the local Board of Health within 10 days of completing public notification. Such notification will include a copy of the distributed public notice.

OPTION 2: PWS Proposed Compliance Plan (Requiring MassDEP Approval)

If Option 1 is not selected or the PWS is unable to complete Option 1 requirements, the PWS must submit a proposed Compliance Plan for MassDEP approval. A proposed Compliance Plan MUST include a schedule for returning to compliance with each of the monitoring and reporting violations cited in the NON and address applicable public notification requirements.

The PWS has included a proposed plan for MassDEP review and approval detailing the specific actions it intends to take to return to compliance and, as appropriate, to prevent future noncompliance. It is understood that MassDEP will provide written notification (which may be via e-mail) if the PWS's proposed Compliance Plan and Schedule is approved.

Proposed Compliance Plan Description and Schedule (enclose additional explanation/attachments as necessary):

The PWS contracted McClure Engineering, Inc. (McClure) for certified operations starting in May 2025. McClure began collecting the required samples and submitting the appropriate documentation to the MassDEP.

D Certification - Water Commissioner, Owner, Owner Representative or other Responsible Party:

I certify that under penalty of law I am duly authorized to complete and submit this form on behalf of the public water system identified above and that the information contained herein is true, accurate and complete to the best of my knowledge and belief. I understand that MassDEP may assess civil administrative penalties in accordance with M.G.L. c. 21A, s.16, and 310 CMR 5.00 to any Supplier of Water that fails to comply with the provisions and schedule set forth in a MassDEP-approved Compliance Plan.

Signature: _____

Date: _____

Print Name: _____

Title: _____

Email Address: _____

Phone#: _____

Please complete this response form and return it with all required attachments to:

MassDEP CERO - Drinking Water Program, 8 New Bond Street, Worcester, MA 01606

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

DRINKING WATER NOTICE

Monitoring Requirements Not Met for:

PWS NAME:

MILLBURY IND. PARK/ PARK HILL VILLAGE

We violated monitoring and reporting requirements of the drinking water regulations. Even though this was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this situation.

We are required to monitor your drinking water for specific man-made and naturally occurring contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the monitoring period(s) listed below we did not monitor and/or did not complete all monitoring for the contaminant(s) listed below and therefore cannot be sure of the quality of our drinking water during that time.

WHAT THIS MEANS: There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for and/or report to the Department of Environmental Protection (DEP) during the required monitoring period(s).

| Monitoring Period | Contaminant Group | Violation Comments |
|--------------------|---|--------------------|
| 1/1/2025 1/31/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (JAN) |
| 2/1/2025 2/28/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (FEB) |
| 3/1/2025 3/31/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (MAR) |
| 4/1/2025 4/30/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (APR) |
| 4/1/2025 4/30/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (APR) |

STEPS WE ARE TAKING:

In response to monitoring and reporting violations of the Massachusetts Drinking Water Regulations, our system is taking the following corrective actions:

1. We are notifying our customers of the violation(s) by providing this public notice to you as well as submitting a copy of this public notice to the MassDEP and local board of health.
2. Sample Collection (check appropriate boxes):
 - We have scheduled to collect and analyze sample(s) for the contaminants listed above and will submit copies of the sampling results to the MassDEP upon completion.
 - We have already collected and analyzed sample(s) for the contaminants listed above and have submitted copies of the sampling results to the DEP. These contaminant(s) were collected AFTER the required monitoring period(s) on: _____ [Date].
3. We will continue to collect samples for all contaminants according to our most recent sampling schedule.
4. Other Corrective Actions Taken:

CONTACT INFORMATION:

Please share this information with all people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information or questions regarding this notice, please contact:

Responsible Party Name: _____ at Phone #: _____

CERTIFICATION:

DEP Reference Number: **NON-CE-25-5D00020872-CSA** PWSID: **2186001**

The Public Water system indicated above hereby affirms that public notice has been provided to consumers in accordance with 310 CMR 22.16 including: delivery, content, format requirements, notification deadlines and that the Public Water system will meet future requirements for notifying new billing units and new customers of the violation. I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Notice Distributed by: CCR on 7/1/2026
[Delivery Method] [Date]

Notice Distributed by: _____ on _____
[Delivery Method] [Date]

Signature of Responsible Party

Date

**Massachusetts Department of Environmental Protection
Drinking Water Program
PUBLIC NOTIFICATION**

CERTIFICATION

Make sure to send your regional office of the MassDEP Drinking Water Program and local Board of Health a copy of each type of notice and a certification that you have met all the public notice requirements within ten days after issuing the notice (310 CMR 22.15(3)b).

PWSID: **2186001**

DEP Reference Number: **NON-CE-25-5D00020872-CSA**

PWS NAME: **MILLBURY IND. PARK/ PARK HILL VILLAGE**

TOWN: **MILLBURY**

CLASS: **COM**

For Monitoring and/or Reporting Violation(s) Occurring on:

| Monitoring Period | Contaminant Group | Violation Comments |
|--------------------|---|--------------------|
| 1/1/2025 1/31/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (JAN) |
| 2/1/2025 2/28/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (FEB) |
| 3/1/2025 3/31/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (MAR) |
| 4/1/2025 4/30/2025 | REVISED TOTAL COLIFORM RULE | TC001, TC002 (APR) |
| 4/1/2025 4/30/2025 | INTERIM ENHANCED SURFACE WATER TREATMENT RULE | SWTR FORM G (APR) |

The Public Water system indicated above hereby affirms that public notice has been provided to consumers in accordance with 310 CMR 22.16 including: delivery, content, format requirements, notification deadlines and that the Public Water system will meet future requirements for notifying new billing units and new customers of the violation.

Delivery Method(s) and Date(s) of Delivery: Check one or more method as applicable, and fill in appropriate date(s).

Community systems (COM):

- Direct Mail on (Date): _____
- Hand Delivery on (Date): _____
- Newspaper 1-day advertisement on (Date): _____
- CCR (by direct delivery only) on (Date): 7/1/2026
- Other _____ on (Date): _____

Non-community systems (NTNC and TNC):

- Direct Mail on (Date): _____
- Hand Delivery on (Date): _____
- Posting for minimum of 7-days in conspicuous locations on (Date): _____
- Other _____ on (Date): _____

I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Print Name

Signature of Responsible Party

Date

SUBMIT THIS FORM WITH A COPY OF YOUR PUBLIC NOTICE(S) TO MassDEP AND LOCAL BOARD OF HEALTH WITHIN 10 DAYS AFTER ISSUING THE NOTICE